



CERTIFICATE NUMBER

01-LD234401/1-PDA

DATE

25 April 2007

ABS TECHNICAL OFFICE

London Engineering Department

CERTIFICATE OF Design Assessment

This is to Certify that a representative of this Bureau did, at the request of
CMP Products

assess design plans and data for the below listed product. This assessment is a representation by the Bureau as to the degree of compliance the design exhibits with applicable sections of the Rules. This assessment does not waive unit certification or classification procedures required by ABS Rules for products to be installed in ABS classed vessels or facilities. This certificate, by itself, does not reflect that the product is Type Approved. The scope and limitations of this assessment are detailed on the pages attached to this certificate. It will remain valid as noted below or until the Rules or specifications used in the assessment are revised (whichever occurs first).

PRODUCT: Cable, Glands and Accessories

MODEL: BW, BWL, A2, CW, E1W, CX/Z, E1X/Z, E2W, A2P Plastic Glands

ABS RULE: 2007 Steel Vessel Rules Sections 1-1-4/7.7, 4-8-3/1.7, 4-8-3/13 and 4-8-4/27.5.

OTHER STANDARD: BS 6121, BS EN 50262; IEC 60079-1;

AMERICAN BUREAU OF SHIPPING

Jean-Claude G. Dennemont

Engineering Type Approval Co-ordinator

CMP Products

Glasshouse Street
St. Peters
Newcastle-upon-Tyne
NE6 1BE
United Kingdom
Telephone: +44-191 265 7411
Fax: +44-191 265 0581

Product: Cable, Glands and Accessories

Model: BW, BWL, A2, CW, E1W, CX/Z, E1X/Z, E2W, A2P Plastic Glands

Intended Service:

Use with various types of cable in safe areas on ships and offshore units.

Description:

Cable Glands of Non-Certified-Safe Type, Models BW, BWL, A2, CW, E1W, CX/Z, E1X/Z, E2W, A2P Plastic Glands

Ratings:

Not applicable

Service Restrictions:

Unit Certification is not required for this product.

Comments:

Safe area application only, not to be used in hazardous location.

Term of Validity:

This Design Assessment Certificate number 01-LD234401/1-PDA, dated 25/Apr/2007 will expire on 24/Apr/2012 or at an earlier date should there be alterations to the product's design or changes to the referenced ABS Rules and other specifications, which affect the product. Product use on or after 1 January 2008, will be subject to compliance with the ABS Rules or specifications in effect when the vessel, MODU or facility is contracted. The product's acceptability on board ABS-classed vessels or facilities is defined in the service restrictions of this certificate.

STANDARDS**ABS Rules:**

2007 Steel Vessel Rules Sections 1-1-4/7.7, 4-8-3/1.7, 4-8-3/13 and 4-8-4/27.5.

National:

BS 6121, BS EN 50262

International:

IEC 60079-1

